


North State Street Format Change

Fire Dept. Notice NOTICE TO ALL VENDORS



NORTH STATE STREET
Curbside Booths Beginning July 2021
Not to Scale and format subject to change



NOTICE TO ALL VENDORS

Tents/Canopies: In accordance with Carlsbad Municipal Code Chapter 17 and California Code of Regulations Title 19, you are hereby notified that any material used as a tent, canopy, awning, or siding must be made from nonflammable material or flame-resistant fabric in accordance with the standards listed in California Code of Regulations Title 19.

Flame Resistance: Material must be either inherently flame-resistant fabric approved by the State Fire Marshal or has been made flame resistant treated with an approved process. Certificate of Flame Resistance affirming the requirements shall be made available upon request of the Fire Department.

Label: All tents, canopies, sidewalls, shall be labelled in accordance with California Code of Regulations Title 19. Each section of top and sidewall shall have a durable label bearing the following information: Seal of Registration or Certification Statement that the materials used in the manufacture or the item meet the flame-resistance requirements of CPAI-84.

Fuel Cans: Fuel cans must be listed (UL or FM) safety can with self-closing lid and a non-sparking flame arrestor. Cans must be stored a minimum of 50 feet from canopies and refueling shall be no closer than 20 feet.

COOKING VENDORS - ADDITIONAL INFORMATION

Cooking Tents: tents used for cooking must be separated from other tents by at least 20 feet.

Outdoor Cooking that produces sparks or grease-laden vapors occur at least 20 feet from any tent or membrane structure.

Combustible materials must be located a minimum of 10 feet from cooking operations and all heat-producing equipment.

Fire Extinguishers: A fire extinguisher rated rating of **2A-20B:C** or larger is required. In addition, a **Class K fire extinguisher** is required where there is a potential for fire due to cooking with vegetable or animal oils and fats (i.e. grilling and deep fat fryers).

All propane cylinders (including in-use and spares) shall be securely fastened in place to prevent movement. Propane bottles not currently in use shall be stored minimum 10 feet from sources of heat and secured.

If it is found that any item is not compliant with any of these requirements, those items or materials in question shall be removed from the site of this event. If you are found to not comply with this order then the appropriate actions up to exclusion from this event may be warranted.

SEE REVERSE FOR NTH STATE MAP 03/15/22