

ENCINITAS FIRE DEPARTMENT

505 S. Vulcan Avenue, Encinitas, CA 92024.

Fire Prevention Bureau

Phone 760-633-2820 Fax 760-943-2226

EVENT: DEMA Fall Street Fair
ADDRESS: South Coast Highway 101
DATE:

The event listed above has the following conditions of approval:

1. Maintain a minimum of (3) feet of clearance around all fire hydrants and fire protection equipment.
2. Any use of City Fire Hydrants shall be approved by the Water District. Notify Encinitas Fire Department if use of fire hydrant(s) is proposed.
3. Electrical extension cords, outlet boxes and power taps shall be sized properly and capable of providing electricity to devices without being subject to overload.
4. Any electrical cords crossing walkways or roadways shall be protected from damage and secured to prevent tripping hazards.
5. Requirements for cooking and heating of food:
 - **ALL FOOD VENDORS, INCLUDING FOOD TRUCKS** that use cooking appliances such as: deep fat fryers, griddles, stoves, woks or other appliances that produce grease laden vapors shall provide a Class "K" rated fire extinguisher in addition to the 2A 10BC required fire extinguisher. The fire extinguishers must be serviced within the last year with a service tag attached and must be visible and accessible.
 - Charcoal/Wood Barbecue Cooking
 1. Charcoal/Wood barbecue cooking is prohibited inside of booths.
 2. Charcoal/Wood cooking shall be performed only in areas away from public access and shall be located a minimum of 10 feet from any booth with a minimum of 15 feet from any permanent structure.
 3. Only commercially sold charcoal lighter fluid or electric starters may be used; no gasoline, kerosene, etc.
 4. Coals shall be disposed of only in metal containers that have been designed for such use. Dumping coals in trash containers is prohibited.
6. All Compressed Gas tanks shall be secured with heavy rope or chain and be stored in a safe manner away from open flame.
7. Spare generator fuel shall not exceed 10 gallons and containers shall be stored out of public reach/access.
8. Generators and other fuel powered equipment shall not be refueled within 50 feet of canopies, tents, stages or booths.

9. No open flames permitted, such as candles or other open flame devices other than approved cooking appliances for food vendors.
10. Booths, tables, chairs, or any other event equipment shall not block or interfere with any exit, exit path, elevator door, entrance gate, stair, etc.
11. Tablecloths, fabric or other cloth material used in vendor booths shall not be frayed or torn. Cloth table coverings shall be kept a minimum of 10 feet from any open flame or heat source and shall be kept a minimum of 6 inches from the ground.
12. All party rental businesses that set-up any tents; canopies; stages; generators; etc. shall submit a plan to the fire department for approval a minimum of two weeks in advance of the event.

BEER GARDEN:

1. Post an occupant load sign: **400 persons max, including staff and vendors inside of the enclosed area.**
2. A minimum of (2) exits are required, minimum of 6 feet wide each.
3. Exits shall be free and clear and accessible at all times.
4. Maintain a minimum of 44 inches between tables/chairs, aisles, and paths to exits.
5. Exit signs shall be posted in a visible location, clearly showing the location of required exits.
6. Fire extinguishers shall be provided inside the fenced area and have a current service tag, fully charged and serviced within last year. Maximum travel distance to a fire extinguisher shall not exceed 75 feet.
7. Fire Extinguishers shall be mounted between 4 feet and 5 feet to the top of the extinguisher.
8. No Smoking signs shall be posted in a visible location at entrance.

Reviewed by: Hans Schmidt

Date: 10/24/18